

Town of Waverly Hall, Ga. System ID# 1450003

2016 ANNUAL

CONSUMER CONFIDENCE REPORT

(706) 582-2381

This report includes data collected between January 2016 – December 2016

YOUR DRINKING WATER IS SAFE

The test results enclosed will show that your
Drinking water meets water quality standards.

THE SOURCES

The Town of Waverly Hall receives water from two municipal ground wells. The wells are located on Storey Drive and Slaughter Drive. These wells are approximately 400 feet deep. This source is commonly called Crystalline Rock Aquifer.

TOWN OF WAVERLY MONITORING RESPONSIBILITIES

The Town of Waverly Hall is mandated by the Ga. Dept. of Natural Resources Environmental Protection Division. We are required by the EPD to provide periodical samples for Lead and Copper, Radionuclides, Disinfection By Products of Chlorine TTHM/HAA5, Nitrate-Nitrite, Inorganics and Microbiology/Bac-T. We are also responsible for maintaining a chlorine residual of at least a .2mg/l at the most remote point of distribution. This is to ensure that our water remains safe from harmful bacteria throughout distribution. We are pleased to report that all of the samples showed negative for harmful bacteria.

Contaminant	MCL	MCLG	Quarterly Aver. (Amount Detected)	Does it Meet Standards
Total Trihalomethanes (TTHM) ppb	80	N/A	8.9 ug/L	YES
Haloacetic Acids (HAA), ppb	60	N/A	<6 ug/L	YES
Fluoride ppm	4	4	0.9	YES
Nitrate-Nitrite ppm	10	10	0.22	YES

Contaminant	MCLG	Max Allowed MCL	# of Positive Samples
E.Coli	ZERO	1 per 100 mL	0 of 12 samples tested positive

MCL: Maximum

Containment Level

MCLG: Maximum Containment Level Goal

PPM: Parts per million

Lead and Copper in Drinking water

Lead 90th Percentile 0 ppb (ug/L)

The action level for Lead is 15 ppb

Copper 90th Percentile 72 ppb (ug/L)

The action level for Copper is 1300 ppb

Note: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from material and components associated with service lines and home plumbing. Waverly Hall Water Works is responsible for providing high quality drinking water control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using for drinking water or for cooking. More information on lead in drinking water is available from the Safe Drinking Water Hotline or @ <http://www.epa.gov/safewater/lead>

VIOLATIONS AND PUBLIC NOTICE

None-Compliance for Lead and Copper 10/01/2016

None- Monitoring Violation for Nitrate-Nitrite *Compliance achieved 12/13/16

QUESTIONS AND ANSWERS

For more information about your drinking water contact the Town clerk at office (706)582-2381