

Town of Waverly Hall, Ga. System ID# 1450003
2023 ANNUAL
CONSUMER CONFIDENCE REPORT
(706) 582-2381

This report includes data collected between January 2023 – December 2023

YOUR DRINKING WATER IS SAFE
The test results enclosed will show that your
Drinking water meets water quality standards.

THE SOURCES

The town of Waverly Hall gets its water from two municipal ground wells. The wells are located on Storey Drive and Slaughter Drive. These wells are approximately 400 feet deep. This source is commonly called Crystalline Rock Aquifer. Water is pumped from the wells at a combined rate of 240gpm. Sodium Hypochlorite 12.5% is added for disinfection and to help protect against harmful bacteria.

TOWN OF WAVERLY MONITORING RESPONSIBILITIES

The Town of Waverly Hall is mandated by the Ga. Dept. of Natural Resources Environmental Protection Division. We are required by the EPD to provide periodical samples for Lead and Copper, Radionuclides, Disinfection By Products of Chlorine TTHM/HAA5, Nitrate-Nitrite, Inorganics and Microbiology/Bac-T. We are also responsible for maintaining a chlorine residual of at least .2mg/l at the most remote point of distribution. This is to ensure that our water remains safe from harmful bacteria throughout distribution.

Contaminant	MC L	MCLG	Quarterly Aver. Or (Highest Amount Detected)	Range of Detection	Does it Meet Standards
Total Trihalomethanes (TTHM) ppb	80	N/A	100.2	100.2 – 100.2	YES
Haloacetic Acids (HAA), ppb	60	N/A	59.2	59.2 – 59.2	YES
Fluoride ppm	4	4	.7	0 - .96	YES
Gros alpha excluding radon and uranium 11/09/22	5	zero	4.03	4.03 – 4.03	YES
Chlorine	4	NA	1	0 – 0.5	YES
Nitrate-Nitrite ppm	10	10	1	0.51	YES

Contaminant	MCLG	Max Allowed MCL	# of Positive Samples
E.Coli	ZERO	1 per 100 mL	0 of All samples tested positive

MCL: Maximum Containment Level
MCLG: Maximum Containment Level Goal
PPM: Parts per million
PPB: Parts per billion

Lead and Copper in Drinking water

Last Samples Taken were 2023 Copper results 90th Percentile .29 ppm MCLG 1.3ppm AL 1.3ppm Violation NO

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as person with cancer undergoing chemotherapy, persons who have undergone transplants, people with HIV/AIDS or other immune system disorders, some elderly infants can be particularly at risk from infection. These people should seek advice about drinking their drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infections by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791)

Drinking water, including bottle water may reasonably be expected to contain at least small amounts of contaminants . The presents of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (1800-426-4791)

Note: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from material and components associated with service lines and home plumbing. When your water has been sitting for several hours you can minimize the potential for lead exposure by flushing your tap for 30 sec. to 2 mins. Before using for drinking water or for cooking. More information on lead in drinking water is available from the Safe Drinking Water Hot line or @ <http://www.epa.gov/safewater/lead>

VIOLATIONS AND PUBLIC NOTICE

The lead and copper rule protects public health by minimizing lead and copper levels in drinking water, primarily by reducing corrosivity. Lead and copper enter drinking water mainly from corrosion of lead and copper containing plumbing material.

Violation Type	Violation begin	Violation end	Explanation
Follow-up or routine tap M/R (LCR)	10-01-2023	2023	We submitted our drinking water to the lab for the period indicated. The drinking water did not reach the lab within the required hold times so they were not analyzed. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.
Public notice lined to violation	03/09/2023	2023	Failure of adequate notification of drinking water consumers about a violation of the drinking water regulations.

QUESTIONS AND ANSWERS For more information about your drinking water contact the Town Clerk at office (706)582-2381